

TAMIL NADU GENERATION AND DISTRIBUTION CORPORATION LTD.
Technical Branch

144, Anna Salai,
Chennai – 2.

Memo No.CE/Comml/SE/Comml/EE3/AEE3/F.ODS/D.44/2018, dt 17.02.2018

Sub:-Electricity – Extension of supply – One day service connection in respect of LT Domestic and Commercial service connections (other than special and multi-storeyed buildings) – Clarification issued - Reg.

Ref:- 1.Memo No.SE/IEMC/EE3/AEE1/9323/90-1, dated 17-01-1990
2.Memo No.CE/Comml/SE/Comml/EE3/AEE3/F.Oneday SC scheme/
D.104/2017, dated 14.06.2017
3.Lr.No.CE/D/CBE/AEE/Safety/F.CPC 12-10-2017/D-14/2018, dt 18-1-18
4.Lr.No.CE/D/CBE/AEE/Safety/F.CPC 12-10-2017/D-268/17, dt 15-11-17

In continuation to the instruction on implementation of 'one day service connection scheme' issued vide reference (2) cited, the Chief Engineer/Distribution/Coimbatore Region vide references (2) and (3) cited has requested clarification whether the distance of the building from the electricity mains of the TANGEDCO be 120 feet or 100 feet for effecting mere service connections.

In this regard, it is clarified that the Domestic and Commercial buildings which require low tension electricity service connections should be within 100 feet from the electricity mains of TANGEDCO and if so, the electricity service connection can be effected on the same day or a maximum time of 48 hours in cases which involve road cut for laying of underground service connection cable.

The distance of 100 feet shall be followed for all mere service categories subject to the ground clearance and other safety aspects as required under Central Electricity Authority (Measures relating to safety and electric supply) Regulations, 2010.

Further, the earlier instruction issued vide reference (1) cited on this issue is cancelled herewith.

Sd/- dated 17-02-2018
Chief Engineer/Commercial
for Director (Distribution)

To
Chief Engineer/ Distribution/Coimbatore Region.

Copy to all the Chief Engineers/Distribution Regions
Copy to all the Superintending Engineers/EDCs.
Copy to the Executive Assistant to CMD/TANGEDCO
Copy to the Personal Assistant to the DGP (Vigilance)/TANGEDCO/Chennai – 2.
Copy to the Executive Assistant to Director (Distribution)