

## TAMILNADU POWER DISTRIBUTION CORPORATION LTD

Research & Development –Energy meters and CT & PT testing TNPDCCL laboratories one at Wallajah Road, Chennai (Permanent lab) and two mobile labs each at Tirunelveli and Udumalpet – Revision of Charges and discount for testing/calibration of HT AC Static meters with ABT compliance -Administrative approval – Accorded.

(Technical Branch)

(Per) MD TNPDCCL No.27

Dated 11, May 2026,  
Prabava varudam, Sithirai 28,  
Thiruvalluvar Aandu-2057.

**READ:**1.B.P. (Per) CMD TANGEDCO No.202 dt 22.09.22.  
2.CMD/TNPDCCL's note approval dt.08.04.2026.

### PROCEEDINGS:

After careful consideration of the proposal submitted by Chief Engineer/ Commercial and R&D, Administrative approval is hereby accorded for revising the charges and discount fixed in B.P. (Per) CMD TANGEDCO No.202 dt 22.09.22 for testing /calibration of third party HT AC Static meters with ABT compliance at NABL accredited TNPDCCL laboratories at Chennai, Tirunelveli and Udumalpet as follows.

### **I.TESTING/CALIBRATION CHARGES FOR ABT METERS**

Sl. No.	Meter Type	Tests	Existing Charges in Rs. per meter	Revised charges in Rs. per meter
1.	Testing Charges for testing HT AC Static meters with ABT compliance.	<b><u>Bidirectional Meter</u></b> Accuracy test (4 modes) No load test Starting current test Meter Constant test Verification of ABT features	20,000	10,000
		<b><u>Unidirectional Meter</u></b> Accuracy test (2 modes ) No load test Starting current test Meter Constant test Verification of ABT features.	14,000	

2.	Calibration Charges for calibration of HT AC Static meters with ABT compliance.	<b><u>Bidirectional Meter</u></b> Accuracy test and Verification of ABT features. (4 modes)	20,000	10,000
		<b><u>Unidirectional Meter</u></b> Accuracy test and Verification of ABT features.(2 modes)	14,000	

## II. Revised Discount and Charges as applicable:

No. of meters	Discount in %	Charges in Rs. Per meter for both Bi-Directional & Uni-Directional
1	0	10,000
2	20	8,000
3	25	7,500
4	30	7,000
5	35	6,500
6	40	6,000
7	45	5,500
8 and above	50	5,000

(BY ORDER OF THE CMD/TNPDCL)

**R.SRIDHARAN**  
Chief Engineer,  
Commercial and R&D.

To

The Chief Engineer/Commercial and R&D/TNPDCL, Chennai-2.

Copy submitted to the Director (Distribution) /TNPDCL/Chennai-2.

Copy submitted to the Director (Technical)/TNGECL/Chennai-2.

Copy submitted to the Director/Finance/TNPDCL/Chennai-2.

Copy to all the Chief Engineers /Distribution /TNPDCL.

Copy to the Chief Engineer/NCES/TNGECL/Chennai-02.

Copy to the Chief Financial Controller/General/ TNPDCL /Chennai-2.


Copy to the Superintending Engineer/R&D/Chennai-2.

Copy to the Executive Assistant/Director (Distribution)/TNPDCL /Chennai-2.

Copy to the Executive Engineer/TNPDCL Testing Laboratory, Chennai-2.

Copy to the Executive Engineer/TNPDCL Mobile Laboratory, Tirunelveli.  
Copy to the Assistant Personnel Officer/Tamil Development for Publication in  
Bulletin/ TNPDCL, Chennai-2.  
Copy to B.P. Section, Administrative Branch, Chennai-2.  
Copy to the SE / Computer Centre – for website update.

TRUECOPY // FORWARDED// BY ORDER

  
EXECUTIVE ENGINEER,(i/c)  
TNPDCL Testing Laboratory,  
Chennai-02.